



C&C AIR TROUBLESHOOTING TIPS

FURNACE AND AIR CONDITIONING

732-495-0600



- Is your thermostat correctly set? (It should be set to Heating or Cooling and on AUTO)
- Have your circuit breakers been tripped?
- Is your furnace door completely closed?
- Have you changed your filters recently? They should be changed at least once a year.
- If we have recently had snow, please check to ensure that the plastic flue pipe on the outside of your home is clear of all snow and ice. If not, carefully remove the debris and your furnace should start back up shortly.

If none of the above helps, please call us at 732-495-0600 for a service call! Thank you!



C&C AIR CONDITIONING & HEATING
HOME PERFORMANCE

752 Highway 36
Belford, NJ 07718
732-495-0600 Fax: 732-495-6040
www.candcair.com